



Public Charter High School

MEMORANDUM

To: Whom It May Concern
CC: n/a
From: David Schlossman, Chief Operating Officer
Date: August 18, 2017
Re: Water Test Notice

This memo describes the results of routine water testing at Thurgood Marshall Academy and the school's corrective action plan.

Each year, Thurgood Marshall Academy contracts with an independent environmental analysis service for routine testing of water outlets at Thurgood Marshall Academy (excluding those, such as janitorial or lab sinks, that should never be used as a source of drinking water and are so marked).

On August 18, 2017, Thurgood Marshall Academy received results from the summer 2017 routine testing showing slightly elevated levels of lead in one sink. The source is a kitchen sink used for washing utensils. ***The sink is not a source of student drinking water.***

Thurgood Marshall Academy immediately implemented the following Corrective Action Plan:

1. Immediately, the school took the sink Out Of Service.
2. The school will install a filter on the sink.
3. The school will have the sink re-tested by the independent contractor.
4. Only after results show non-elevated levels of lead will the sink be returned to service.

For further information please contact:

David Schlossman
Chief Operating Officer
202-276-4722
dschlossman@tmapchs.org