



Public Charter High School

# MEMORANDUM

To: Whom It May Concern  
CC: n/a  
From: David Schlossman, Chief Operating Officer  
Date: June 5, 2018  
Re: Water Test Results

This memo describes the results of routine water testing at Thurgood Marshall Academy and the corrective action plan that has been completed.

The DC Public Charter School Board (DC PCSB) is working with all DC charter schools, including Thurgood Marshall Academy, to conduct routine water testing. Previously, the school undertook its own routine testing and worked independently and with the DC PCSB to install filters on several faucets.

On May 23, 2018, Thurgood Marshall Academy received results from Spring 2018 routine testing showing slightly elevated levels of lead in two sinks: a kitchen sink used for washing utensils, and a sink in the library office area rarely used for any purpose. ***Neither sink is a source of student drinking water.***

***The following corrective action plan has been completed:***

1. The sinks were taken Out Of Service.
2. Water filter cartridges installed on the sinks were changed.
3. The water from the affected sinks was re-tested (by the same water safety contractor—who is independent of the school—that conducted the first test).
4. Tests showed the sinks' water was now acceptable, and the sinks were returned to service.

For further information please contact:

David Schlossman  
Chief Operating Officer  
202-276-4722  
dschlossman@tmapchs.org



# Thurgood Marshall Academy PCS - Lead in Water Test Results



## FY18 Filter Test - Plumbing Check Retest

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Thurgood Marshall Academy PCS	WS-119-002	Food Prep Sink	Ground	In kitchen	-	Right	WF-102017-119002-01	6/4/18	FT-FY18-102017-119002	<1	<1
Thurgood Marshall Academy PCS	WS-119-008	Classroom Faucet	2	In library	-	-	WF-102017-119008-01	6/4/18	FT-FY18-102017-119008	<1	<1



# Thurgood Marshall Academy PCS - Lead in Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Thurgood Marshall Academy PCS	WS-119-001	Food Prep Sink	Ground	In kitchen	-	Left	WF-102017-119001-01	5/20/18	FT-FY18-102017-119001	2.5	<1
Thurgood Marshall Academy PCS	WS-119-003	Cooler	Ground	In hallway adjacent to lunch room	-	-	WF-102017-119003-01	5/20/18	FT-FY18-102017-119003	<1	<1
Thurgood Marshall Academy PCS	WS-119-004	Health Suite	Ground	In health suite	-	-	WF-102017-119004-01	5/20/18	FT-FY18-102017-119004	<1	<1
Thurgood Marshall Academy PCS	WS-119-005	Cooler	Ground	In hallway adjacent to music room 012	-	-	WF-102017-119005-01	5/20/18	FT-FY18-102017-119005	<1	<1
Thurgood Marshall Academy PCS	WS-119-006	Cooler	1	In hallway adjacent to science room 112	-	-	WF-102017-119006-01	5/20/18	FT-FY18-102017-119006	<1	<1
Thurgood Marshall Academy PCS	WS-119-007	Cooler	2	In hallway adjacent to library room 213	-	-	WF-102017-119007-01	5/20/18	FT-FY18-102017-119007	<1	<1
Thurgood Marshall Academy PCS	WS-119-009	Cooler	2	In hallway adjacent to room 206	-	-	WF-102017-119009-01	5/20/18	FT-FY18-102017-119009	<1	<1
Thurgood Marshall Academy PCS	WS-119-010	Break Room	2	In teachers' lounge	-	-	WF-102017-119010-01	5/20/18	FT-FY18-102017-119010	<1	<1
Thurgood Marshall Academy PCS	WS-119-011	Food Prep Sink	Ground	In kitchen	-	-	WF-102017-119011-01	5/20/18	FT-FY18-102017-119011	<1	4.1
Thurgood Marshall Academy PCS	WS-119-012	Health Suite	Ground	In health suite	-	-	WF-102017-119012-01	5/20/18	FT-FY18-102017-119012	<1	<1
Thurgood Marshall Academy PCS	WS-119-013	Break Room	2	In teachers lounge (coffee maker)	-	-	WF-112017-119013-01	N/A	FT-FY18-102017-119013	N/A	

Greater than 5 ppb - Devices Requiring Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Thurgood Marshall Academy PCS	WS-119-002	Food Prep Sink	Ground	In kitchen	-	Right	WF-102017-119002-01	5/20/18	FT-FY18-102017-119002	5.7	<1
Thurgood Marshall Academy PCS	WS-119-008	Classroom Faucet	2	In library	-	-	WF-102017-119008-01	5/20/18	FT-FY18-102017-119008	6.2	<1

Both sinks re-tested as acceptable on 6/4/2018--see report, above.

