



Public Charter High School

MEMORANDUM

To: Whom It May Concern
From: David Schlossman, Chief Operating Officer
Date: August 15, 2019
Re: Water Test Results

This memo describes the results of routine water testing at Thurgood Marshall Academy.

During the summer of 2019, Thurgood Marshall Academy contracted with SaLUT, Inc., an independent environmental testing company, to test drinking water at the Thurgood Marshall Academy's facility. SaLUT took samples and had them tested at an independent laboratory, AMA Analytical Services, Inc.

Thurgood Marshall Academy received the results on August 14, 2019. The results show that no further action is recommended regarding drinking water at Thurgood Marshall Academy. Details appear below.

For further information please contact:

David Schlossman
Chief Operating Officer
202-276-4722
dschlossman@tmapchs.org

IMPORTANT NOTICE: LEAD IN WATER **SAMPLE RESULTS**

Thurgood Marshall PCS

LEAD IN WATER SAMPLE RESULTS

On August 7th, 2019, twenty-four (24) lead water samples were collected from Thurgood Marshall PCS. The samples were submitted to a certified laboratory for lead in water analysis using current US EPA methodology. Of these 24 lead water samples, none had levels of lead exceeding the action level (AL) of 5 parts per billion (ppb) for lead in drinking water in school buildings so no further remedial steps are required.

Below is a brief summary of the test results for Thurgood Marshall PCS.

Date of Sample Collection	August 7, 2019
Date of Sample Analysis	August 13, 2019
# of Samples Collected	24
# of Outlets \geq 5 ppb	0
Low Value (ppb)	< 1 ppb
High Value (ppb)	4.8 ppb
Follow-up Remediation Required (Samples \geq 5 ppb)	none

Thurgood Marshall PCS - Lead in Water Test Results

FY19 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Sample ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Thurgood Marshall Academy PCS	WS-119-001	Food Prep Sink	Ground	In kitchen	-	Left	WF-032019-119001-02	8/13/19	FT-FY19-032019-119001	<1	<1
Thurgood Marshall Academy PCS	WS-119-002	Food Prep Sink	Ground	In kitchen	-	Right	WF-032019-119002-02	8/13/19	FT-FY19-032019-119002	4.1	<1
Thurgood Marshall Academy PCS	WS-119-003	Cooler	Ground	In hallway adjacent to lunch room	-	-	WF-032019-119003-02	8/13/19	FT-FY19-032019-119003	<1	<1
Thurgood Marshall Academy PCS	WS-119-004	Health Suite	Ground	In health suite	-	-	WF-032019-119004-02	8/13/19	FT-FY19-032019-119004	<1	<1
Thurgood Marshall Academy PCS	WS-119-005	Cooler	Ground	In hallway adjacent to music room 012	-	-	WF-032019-119005-02	8/13/19	FT-FY19-032019-119005	<1	<1
Thurgood Marshall Academy PCS	WS-119-006	Cooler	1	In hallway adjacent to science room 112	-	-	WF-032019-119006-02	8/13/19	FT-FY19-032019-119006	<1	<1
Thurgood Marshall Academy PCS	WS-119-007	Cooler	2	In hallway adjacent to library room 213	-	-	WF-032019-119007-02	8/13/19	FT-FY19-032019-119007	<1	<1
Thurgood Marshall Academy PCS	WS-119-009	Cooler	2	In hallway adjacent to room 206	-	-	WF-032019-119009-02	8/13/19	FT-FY19-032019-119009	<1	<1
Thurgood Marshall Academy PCS	WS-119-010	Break Room	2	In teachers' lounge	-	-	WF-032019-119010-02	8/13/19	FT-FY19-032019-119010	<1	<1
Thurgood Marshall Academy PCS	WS-119-011	Food Prep Sink	Ground	In kitchen	-	-	WF-032019-119011-02	8/13/19	FT-FY19-032019-119011	4.8	<1
Thurgood Marshall Academy PCS	WS-119-012	Health Suite	Ground	In health suite	-	-	WF-032019-119012-02	8/13/19	FT-FY19-032019-119012	2.0	<1
Thurgood Marshall Academy PCS	WS-119-013	Break Room	2	In teachers lounge (coffee maker)	-	-	WF-112017-119013-02	8/13/19	FT-FY19-032019-119013	<1	<1